

Außenstelle Erwitte · Auf den Thränen 2 · 59597 Erwitte · Telefon (02943) 897 · Telefax (02943) 897 33 · E-Mail: erwitte@mpanrw.de

Report of the classification of the reaction to fire performance

No. 230010415-3

issued 08.04.2016

English version

Sponsor

ORAFOL Europe GmbH Orafolstraße 2

16515 Oranienburg

Order

Classification of the reaction to fire performance according to DIN EN 13501-1:2010-01

Date of order: 12.02.2016

Name of the classified product:

High-gloss as soon as matt white and matt black, printable PVC-self-adhesive foils "ORACAL 751C"

This report gives the classification of the above-mentioned building product in accordance to the procedure given in DIN EN 13501-1.

Publishing and copying of classification reports without permission of the MPA NRW is only allowed without any changes of the content and the form of the reports.

The shortened reproduction of classification reports needs the permission of the MPA NRW.

This classification report consists of 3 pages.



1 Description of the building product

Cast PVC-foil for plotter applications with an acrylate-based adhesive coating on one side

Thickness of the PVC-foil without the self-adhesive coating: 0,06 mm

Mass per unit area of the self-adhesive foils: app. 109 g/m²

Colour: a) high-gloss in different colours, b) matt white, c) matt black

2. Test reports and test results supporting the classification

2.1 Test reports

Name of the test laboratory	Sponsor	No. of the test report	Test procedure
MPA NRW	ORAFOL Europe GmbH	230010415-1 of 08.04.16 230010415-2 of 08.04.16	The second state of the second

2.2 Test results

The following test results are the basis of the classification

	Parameter	Number of tests per-	Test results	
Test method			Average values of continously parameter	Requirements of diskrete parameter
DIN EN ISO 11925-2 30 s flaming time	Flamespread ≤150 mm Burning droplets/particles	36		yes no
,	FIGRA _{0.2} in W/s		64	
	FIGRA _{0.4} in W/s		17	
	THR _{600s} in MJ		1,1	
DIN EN 13823	LFS _{edge}	3		< edge
DIIV EIV 13023	SMOGRA in m ² /s ²	IOGRA in m²/s²		
	TSP _{600s} in m ²		45	
	Duration of burning droplets/particles in s		0	



3. Classification and direct field of application

3.1 Reference

This classification was carried out in accordance to the clauses 11 and 14 of the standard DIN EN 13501-1:2010-01.

3.2 Classification

The tested building product in relation to its reaction to fire behaviour is classified as:

The additional classification in relation to smoke production is:

The additional classification in relation to flaming droplets/particles is:

The classification of the reaction to fire performance is therefore:

Fire behaviour	Smoke devel- opment	Flaming droplets
В	s1	d0

i. e. **B - s1,d0**

3.3 Field of application of the product

The classification is valid solely for the product described in clause 1 for the application on gypsum boards as well as on substrates of Euroclass A1 or A2-s1,d0 used in practice with a density of $\geq 525 \text{ kg/m}^3$ and a thickness of $\geq 12 \text{ mm}$. The classification is also valid, if the foil will be printed with colours.

4. Restrictions

This classification report does not represent type approval or certification of the product.

5. Remark

This classification report written in English language is issued additionally to the report written in German language with the same report number. In case of doubt the German version is valid solely.

Erwitte, 08.04.2016

On behalf

Dipl.-Ing. Schreiner

Assistant head of notified testing body

Date of issue of this English version: 08.04.2016

