

Short Form Classification Report No. 17790G

PRODUCT

TRIAPRINT®

SPONSOR

I.P.B. nv

PRODUCT DETAILS

- Total thickness: 2,7 mm – 5,7 mm
- Total surface mass: 600 g/m² – 1600 g/m²
- Nominal thickness of top & bottom layer: 0,17 mm – 0,60 mm (directly proportional to the total thickness)
- Nominal cell diameter: 4 mm – 8 mm
- Use of fire retardants: Yes
- Amount of fire retardants: Known by the laboratory
- Colour: White

FIELD OF APPLICATION

- Freestanding

CLASSIFICATION

B-s1,d0

STANDARDS

Test standard: EN ISO 11925-2:2010/AC:2011 & EN 13823:2010+A1:2014

Classification standard: EN 13501-1-2007+A1:2009

SIGNED

APPROVED

For and on behalf of WFRGENT nv

This short form classification report has been drafted according to EGOLF agreement EGA 08rev2:2013 "Application note: clause 5.10 [5.10/1] – Types of test reports used in fire testing". Whilst the test data and classification provided within this short form report was obtained in a test conducted fully in accordance with the standards EN ISO 11925-2:2010/AC:2011, EN 13823:2010+A1:2014 and EN 13501-1:2007+A1:2009, the presentation of the results in this short form report may not satisfy the requirements of that standard / those standards and EN ISO/IEC 17025:2005/AC:2006. The presentation of the results in this manner is made by agreement with the sponsor and use of the information herein for product assessment, approval or certification purposes will be restricted.

The full classification report No. **17790E** is available at **I.P.B. nv**.

This document is the original version of this report and is written in English. This document may be used only literally and completely for publications. For publications of certain texts, in which this document is mentioned, our permission must be obtained in advance.

The authenticity of the electronic signatures is assured by Belgium Root CA.